

To: All Plan Holders of Record

From: Dalton Flinn, Village Administrator
Village of New Concord, Ohio

***Re: Addendum No. 1
Village of New Concord, Ohio
Main Street Lead Service Line Replacement***

Date: October 15, 2026

This Addendum forms a part of the contract documents and modifies the original bidding documents dated October 2026 and all previous addenda, if any. Acknowledge receipt of this addendum in the space provided in the bid forms. Failure to do so may subject the bidder to disqualification.

BID OPENING DATE

The date of receiving and opening bids shall be changed from October 19, 2026, to October 26, 2026. The time and place shall remain the same.

PROCUREMENT REQUIREMENTS

1. Page BF-05 (Sheet 1 of 2), Scope of Bids, Bid Item 2.0 – System-Side Line Replacement (Long Side): Within the description presented for the scope of the reference pay item, **DELETE** the phrase “with a new corporation stop” from the first sentence.
2. Page BF-05 (Sheet 1 of 2), Scope of Bids, Bid Item 3.0 – System-Side Line Replacement (Short Side): Within the description presented for the scope of the reference pay item, **DELETE** the phrase “with a new corporation stop” from the first sentence.

CONTRACTING REQUIREMENTS

1. Page CF-02 (Sheet 2 of 9), Agreement, Article 3. Contract Time, Item 3.1: **REPLACE** the text “60 calendar days” with the text “90 calendar days”.
2. Page CF-03 (Sheet 1 of 1), Notice to Proceed: **REPLACE** the text “sixty (60)” with the text “ninety (90)”.

PREVAILING WAGES

1. Page PW-01, Prevailing Wage Rates – Following the title, **REPLACE** the text provided on this page in its entirety with the following:

“The Contractor agrees that each individual employed by the Contractor or any Subcontractor and engaged in work on the project under this contract shall be paid the prevailing wage established by the U.S. Department of Labor under the Davis-Bacon and related Acts. This shall occur regardless of any contractual relationship which may be said to exist between the Contractor and any individual or any Subcontractor and any individual.

The Prevailing Wage Determination Schedule for this project is attached for review. These wages are subject to change pending modifications by the Department of Labor. Wage Determination Schedules can be viewed via the internet at <https://sam.gov/wage-determinations> .”

DRAWINGS

1. Sheet 3 of 11, Standard Details – Service Line Replacement: Within this detail **REPLACE** the text “NEW CORP ATTACHMENT FITTINGS (TYP.)” with the text “CONNECT TO EX. CORP ATTACHMENT FITTINGS (TYP.)”.
2. Sheet 3 of 11, Standard Details – Service Line Replacement: Within this detail **REPLACE** the text “NEW K-COPPER WATER SERVICE (TYP.)” with the text “NEW HDPE WATER SERVICE (TYP.)”.
3. Sheet 3 of 11, Standard Details – Service Line Replacement: Within the notes associated with this detail **ADD** Item 4. as follows:

“4. Water Service Line material shall be PE4710 Blue CTS DR9 rated 200 psi (minimum) per ASTM D2737. Material provided shall meet NSF 14 and 61 for potable water use.”

DF:ba

Enclosure